

New Source Review newspaper advertisement for construction permit application, January 20, 2012. The following public notice has been published in the newspaper listed below the advertisement. This newspaper advertisement for a construction permit application was published on January 23, 2012. Public notices are generally published every two weeks. The previous publication of public notices was January 5, 2012.

#### PUBLIC NOTICE

The Tennessee Division of Air Pollution Control (TDAPC) has received requests for construction and/or modification of air contaminant sources as noted below. The proposed construction and/or modification is subject to part 1200-3-9-.01(1)(h) of the Tennessee Air Pollution Control Regulations, which requires a public notification and 30-day public comment period. Interested parties may express their comments and concerns in writing to Mr. Barry R. Stephens, Director, Division of Air Pollution Control, 9<sup>th</sup> Floor, L & C Annex, 401 Church Street, Nashville, Tennessee 37243-1531 within thirty (30) days of the date of this notice. Questions concerning a source may be addressed to the assigned Division personnel at the same address or by calling 615-532-0554.

Individuals with disabilities who wish to participate should contact the Tennessee Department of Environment and Conservation to discuss any auxiliary aids or services needed to facilitate such participation. Such contact may be in person, by writing, telephone, or other means, and should be made no less than ten days prior to the end of the public comment period to allow time to provide such aid or services. Contact the Tennessee Department of Environment and Conservation ADA Coordinator, 12<sup>th</sup> Floor, 401 Church Street, Nashville, TN 37243, 1-866-253-5827. Hearing impaired callers may use the Tennessee Relay Service, 1-(800)-848-0298.

The applicant is Peak 10, Inc. with a mailing address of 425 Duke Drive, Suite 400, Franklin, TN 37067. They seek to obtain an air contaminant permit (Division identification number: 94-0336-01/965290) for construction of an Emergency Power Generation facility at the same address. This proposed operation would consist of four (4) 600kW/804.6 Hp diesel-generation units. Because of the amount and type of emissions, the use of pollution control equipment is not proposed. There would be physical construction. Regulated air contaminants would be emitted by this source. Robert Benjamin is the assigned Division person.

For the Williamson County "Williamson AM"--published once on or before Monday, January 23, 2012

---